

**Material: Boxes:** #16 Gauge Steel with a Black Textured Finish (Standard).

**Door:** #16 Gauge Steel with a Black Textured Finish (Standard), or #16 Gauge Stainless Steel with a #4 Horizontal Brush upon request.

**Hinge:** Concealed Stainless Steel located on the left side.

**Fastener:** #2171 Key change lock.

**Backbox Depth:**  
Semi-Flush: 3.50"

Surface: 4.75"

# of Zones	Model	Indications Arranged		Legend Area		Semi-Flush		Surface		Overall	
		Width	Height	Width	Height	Width	Height	Width	Height	Width	Height
4	BGRA-BL-4	1	4	3.50	1.65	7.50	12.75	8.85	14.25	9.30	14.50
8	BGRA-BL-8	2	4	1.95	1.85	7.50	12.75	8.85	14.25	9.30	14.50
12	BGRA-BL-12	2	6	2.00	1.20	7.50	12.75	8.85	14.25	9.30	14.50
16	BGRA-BL-16	2	8	2.00	0.85	7.50	12.75	8.85	14.25	9.30	14.50
24	BGRB-BL-24	4	6	1.85	1.10	12.00	12.75	13.35	14.25	13.80	14.50
30	RSC-BL-30	6	5	2.00	2.00	20.00	17.25	21.50	18.75	22.00	19.00
36	RSC-BL-36	4	9	3.50	1.10	20.00	17.25	21.50	18.75	22.00	19.00
40	RSC-BL-40	5	8	2.80	1.30	20.00	17.25	21.50	18.75	22.00	19.00
60	RSC-BL-60	5	12	2.80	0.75	20.00	17.25	21.50	18.75	22.00	19.00
88	RSD-BL-88	8	11	1.90	1.30	22.00	22.25	23.50	23.75	24.00	24.00
144	RSE-BL-144	12	12	1.65	1.10	28.00	22.25	29.50	23.75	30.00	24.00
154	RSE-BL-154	14	11	0.93	0.84	28.00	22.25	29.50	23.75	30.00	24.00



## **BACKLIGHTED WINDOW ANNUNCIATOR SPECIFICATION**

---

The annunciator enclosure shall be constructed of cold rolled steel with welded and ground seams for a finished appearance. The backbox shall be finished with a black powder coating. The annunciator door shall have a concealed stainless steel piano hinge and shall be finished in a black powder coating or stainless steel as directed by the engineer. The door shall be secured by a key lock with no other fastener visible.

The annunciator will have dual lamps per zone and black nomenclature on a white background. The lamp wiring shall be neatly harnessed to designated terminal blocks located in the annunciator backbox. The annunciator shall be manufactured by the H.R. Kirkland Company or an approved equal.




# BACKLIGHTED ANNUNCIATORS ORDERING INFORMATION

## Typical Part Number

---

### **BGRA-BL-16**



Backlighted pricing includes two (2) incandescent 24 volt bulbs per point and a translucent mylar grid. Photographic legends can be supplied by Kirkland or placed on a blank mylar grid by the customer. Replacement mylars with photographic grids and legends are available. Records of completed orders are kept on file for future legend additions. Two parallel standard bulbs per point draw 80 mA total @ 24VDC.

## Order Information Required

---

### • Backbox Mounting

Surface or Semi-flush mount

### • Wiring

Hardwired                      Please provide voltage and feed.

Drivers                              Please provide model number of FACP and driver model number.

### • Options

Lamptest                          Pushbutton or Key Switch

Common Trouble                Trouble Circuit to include Led, Buzzer and Silence Switch.

Audible Alert                      Buzzer Circuit to operate from alarm inputs with common Silence Switch.

Please advise if :  
-Software Driven  
-Hardwired  
-Hardwired with subsequent alert

Miscellaneous Switches        Please refer to Accessories section of catalog.

Stainless Steel Door

Power on Led

02080513